

CERTIFICATE OF WATER TANKER
SHUTTLE ACCREDITATION

Presented to

Douro-Dummer Fire Department

Donwood F.S.#1 (8)

Douro F.S.#2 (8)

Warsaw F.S.#4 (8)

North Dummer F.S #5 (Line 6 at County Road 6) (8)

Norwood F.S Ashphodel-Norwood Township (8)

Havelock F.S Havelock-Belmont-Methuen Twp (8)

Lakefield and Young's Point F.F.s Selwyn Twp (8)

Date Test Passed: June 20th 2019

Flow Achieved: 428 I.G.P.M

Liters Per Min: 1940

Two (2) Hour Test Time

Signed: Melissa Rose
Melissa Rose - Principal

This Certificate is valid for 5 years and expires June 20th 2024