

# Fire Protection Survey Services™

2403 Fairgrounds Road  
Washago, Ontario, Canada, L0K 2B0  
Telephone: (249) 359 7231  
E-mail: [fpss@explornet.ca](mailto:fpss@explornet.ca) Website: [www.fpss.ca](http://www.fpss.ca)

## Fire Department Water Tanker Shuttle Accreditation

Presented To: Douro-Dummer Township

### ACCREDITED FIRE STATIONS

F.S. # 1 Donwood (8)

F.S. # 2 Douro (8)

F.S. # 4 Warsaw (8)

F.S. # 1 Ashphodel-Norwood Twp., Norwood (8)

F.S. # 1 Havelock-Belmont-Methuen Twp., Havelock

F.S. # 2 Selwyn Twp., Lakefield (8)

F.S. # 3 Young's Point (8)

Date Test Passed: June 20, 2019

Flow Achieved: 428 I.G.P.M. 1,940 LITERS/MIN.

Two (2) Hour Test Time



Signed: Elaine Rose  
Elaine Rose  
Acting Partner on Behalf of Peter J Rose, F.P.T

This Certificate Expires on: July 1, 2024

**FPSS "Professionalism With Pride"®**